

**ADDITIONAL REQUIREMENTS**









- 1) MINIMUM SIZE WIRE IS #12.
- 2) ALL WIRE SHALL BE LISTED AS SUITABLE FOR WET LOCATIONS.
- 3) ALL RECEPTACLE OUTLETS AND SWITCHES. SHALL BE RATTED FOR 20 AMPS OR GREATER.
- 4) ALL SWITCHES AND OUTLETS SHALL HAVE WATER TIGHT COVERS.
- 5) ALL SWITCHES AND OUTLETS SHALL BE A MINIMUM OF 4' ABOVE THE NORMAL POOL LEVEL AND 30" ABOVE FIRST FLOOR DECKS.
- 6) ALL PLUG-IN DEVICES FOR MOTORS SHALL BE SJ CORD.

Name: \_\_\_\_\_

Address: \_\_\_\_\_

Lot Number: \_\_\_\_\_

Addition: \_\_\_\_\_

- \_\_\_\_\_ Conduit
- \_\_\_\_\_ Buried Conduit
-  GFI Breaker
-  Motor
-  Electrical Warning Signs
-  Light
-  Light with Photocell
-  Distribution Panel
-  Convenience outlet with GFI Protection
-  Switch

**REQUIRED INFORMATION**

PUMP MOTOR SIZE: \_\_\_\_\_ EXISTING? \_\_\_\_\_

HOIST MOTOR SIZE: \_\_\_\_\_

TOTAL LIGHT WATTAGE: \_\_\_\_\_

SERVICE IS: \_\_\_\_\_ AMPS

# OF CIRCUITS: \_\_\_\_\_ @ \_\_\_\_\_ AMPS

Owner's Signature: \_\_\_\_\_

**CONTRACTOR NOTES**

CONDUIT IS SHOWN SCHEMATICALLY. THE EXACT LOCATION WILL BE DETERMINED DURING CONSTRUCTION.

ALL WORK WILL BE DONE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE BY AN ELECTRICAL CONTRACTOR LICENSED BY THE TEXAS DEPARTMENT OF LICENSE AND REGULATION.

SERVICE SIZE: 110V \_\_\_\_\_ / 220V \_\_\_\_\_

SERVICE WIRE SIZE: \_\_\_\_\_

Date: \_\_\_\_\_