

ADDITIONAL REQUIREMENTS

- 1) MINIMUM SIZE WIRE IS #12.
- 2) ALL WIRE SHALL BE LISTED AS SUITABLE FOR WET LOCATIONS.
- 3) ALL RECEPTACLE OUTLETS AND SWITCHES. SHALL BE RATTED FOR 20 AMPS OR GREATER.
- 4) ALL SWITCHES AND OUTLETS SHALL HAVE WATER TIGHT COVERS.
- 5) ALL SWITCHES AND OUTLETS SHALL BE A MINIMUM OF 4' ABOVE THE NORMAL POOL LEVEL AND 30" ABOVE FIRST FLOOR DECKS.
- 6) ALL PLUG-IN DEVICES FOR MOTORS SHALL BE SJ CORD.

Name: _____

Address: _____

Lot Number: _____

Addition: _____

CONTRACTOR NOTES

CONDUIT IS SHOWN SCHEMATICALLY. THE EXACT LOCATION WILL BE DETERMINED DURING CONSTRUCTION.

ALL WORK WILL BE DONE IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE BY AN ELECTRICAL CONTRACTOR LICENSED BY THE TEXAS DEPARTMENT OF LICENSE AND REGULATION.

SERVICE SIZE: 110 V _____ / 220V _____

SERVICE WIRE SIZE: _____

Date: _____

REQUIRED INFORMATION

PUMP MOTOR SIZE: _____ EXISTING? _____

HOIST MOTOR SIZE: _____

TOTAL LIGHT WATTAGE: _____

SERVICE IS: _____ AMPS

OF CIRCUITS: _____ @ _____ AMPS

Owner's Signature: _____

_____ Conduit  GFI Main Breaker

_____ Buried Conduit  Motor



Light



Light with Photocell



Electric Shock Warning Signs



Distribution Panel



Convenience outlet with GFI Protection



Switch